



City of Alachua

ADAM BOUKARI
CITY MANAGER

FINANCE & ADMINISTRATIVE SERVICES
ROBERT A. BONETTI, DIRECTOR

City of Alachua
NW Neighborhood Street Resurfacing Project DEO
Contract #18DB-OM-03-11-02-N14
CDBG Paving and Repaving Project
RFB 2019-01
AMENDMENT NUMBER 3

DATE: January 29, 2019
TO: Prospective Bidders
SUBJECT: Amendment Number 3 to Request for Bids

Amendment initiated and issued by City to Clarify the Purchasing Documents.

- QUESTION:** Alternate #1 is calling for SDR 35 pipe. Due to the depth part of this run is supposed to be SDR 26 per city standards. Clarify how much pipe is to be SDR 35 versus SDR 26 or do we make entire run SDR 26. Cost difference between the 2 types of pipe and fittings & suppliers are requesting clarification.
ANSWER: SDR 26 for the entire run.

*****End of Amendment Number 3*****