Gregory, Trevor

From: Doyle, Adam <Adam.Doyle@dot.state.fl.us>
Sent: Wednesday, January 29, 2020 2:32 PM
To: Kendall, Robin
Cc: Gregory, Trevor; Cavin, Tom; Scanlan, Steven; Emmons, Robert
Subject: RE: Burger King- City of Alachua
Attachments: BK @ Alachua Civil Plans 1.20.2020_HMD SS.pdf

CAUTION: EXTERNAL eMAIL
DO NOT click on links or open attachments from unknown senders or unexpected eMails.

Robin,

Thank you for the updated plans. As we discussed in our 1/7/20 pre-application meeting, we are agreeable to the general concept of the Burger King in this location. As shown in the attached concept, you are removing the existing 2 driveways and re-constructing one driveway to current standards at the median opening on US 441. Based on median spacing standards, you are required to convert the existing full median opening to a directional median opening (also shown in the attached concept). As you stated in your email below, you are required to provide a signed and sealed traffic impact analysis that will be ready in the next week or so. I have no issue with the City of Alachua proceeding with their review utilizing the attached concept plan. Once you submit the permit and traffic study, we will review and provide comments. We will also initiate the public information process involved in a median modification. Feel free to contact me with any further questions.

Adam E. Doyle, P.E.
Permits Manager - Gainesville Operations
5301 NE 39th Avenue
Gainesville FL, 32609
adam.doyle@dot.state.fl.us
(352) 381-4308

From: Kendall, Robin <RKendall@qdi.com>
Sent: Tuesday, January 28, 2020 8:39 AM
To: Doyle, Adam <Adam.Doyle@dot.state.fl.us>
Cc: Gregory, Trevor <TGregory@qdi.com>
Subject: Burger King- City of Alachua

EXTERNAL SENDER: Use caution with links and attachments.

Adam,

The City of Alachua is requiring us to provide documentation that an application for access connection has been submitted to the FDOT.
We can't provide that until we actually make that application and we can't make the application until the traffic study is complete which should be complete within a week.

Per our conversation this morning, attached are the plans we will be submitting to the FDOT once the traffic study is complete.

Is there some document/email that you could provide for inclusion in my submittal to the city that states we met and that subject to review of the traffic study and final permitting the FDOT has no issue with the project?
As discussed, our submittal deadline is Thursday, otherwise we lose a month on permitting with the city.
Your help is appreciated.
Thank you

Robin Kendall
Quality Dining, Inc.
3018 U.S. Highway 301 N.
Suite 100
Tampa, Florida 33619
Direct: 813.559.8256
Cell: 813.690.4913